

NEW JERSEY RESIDENTIAL FIRE EXTINGUISHER REQUIREMENTS

1

**FIRE EXTINGUISHER MUST HAVE A
MINIMUM RATING OF**

2A - 10B:C

AND BE NO MORE THAN 10 POUNDS

FOR EXAMPLE: 3-A:40-B:C rated fire extinguisher
would also be acceptable



2

FIRE EXTINGUISHER MUST BE MOUNTED

- MUST BE ACCESSIBLE & VISIBLE, NOT BEHIND CLOSED DOOR OR CABINET
- SHALL BE WITHIN 10 FEET OF KITCHEN
- LOCATED IN THE PATH OF EGRESS (TOWARDS AN EXIT)
- MUST USE THE MANUFACTURER'S MOUNTING BRACKET
- TOP OF EXTINGUISHER NOT MORE THAN 5 FEET ABOVE FLOOR



3

FIRE EXTINGUISHER MUST BE OPERABLE

- EXTINGUISHER GAUGE SHALL INDICATE A FULL CHARGE
- EXTINGUISHER SHALL BE SERVICED & TAGGED BY SERVICE CONTRACTOR WITHIN THE PAST 12 MONTHS
- OR THE SELLER MUST HAVE A RECEIPT FOR RECENTLY PURCHASED EXTINGUISHER

